

BASIC SEPARATION STANDARDS

1. PARALLEL CONSTRUCTION: THERE SHALL BE AT LEAST 10 FEET HORIZONTAL CLEARANCE BETWEEN PRESSURE DOMESTIC WATER AND RECLAIMED WATER MAINS AND SEWER LINES.
2. PERPENDICULAR CONSTRUCTION (CROSSING): PRESSURE WATER MAINS SHALL BE AT LEAST ONE FOOT ABOVE SANITARY SEWER AND RECLAIMED WATER LINES WHERE THESE LINES MUST CROSS.
3. SPECIAL PROVISIONS: ALTERNATIVE CONSTRUCTION CRITERIA WHERE THE BASIC SEPARATION STANDARDS CANNOT BE ATTAINED ARE SHOWN BELOW:

ZONE	WATER CONSTRUCTION (EXISTING SEWER)
B	1) CLASS 350 D.I.P. WATER MAIN. 2) APPROVED ALTERNATIVES.
C/D	1) CLASS 350 D.I.P. WATER MAIN W/NO JOINT 2) STEEL CASING PER STD. T715 3) APPROVED ALTERNATIVES
A	NO CONSTRUCTION WITHOUT APPROVAL OF TORRANCE MUNICIPAL WATER DEPARTMENT AND STATE OF CALIFORNIA DEPARTMENT OF HEALTH SERVICES.
P	CONSTRUCTION WITHIN THIS AREA PROHIBITED.

ACCOMPANYING STD.'S T700 AND T715.

CITY OF TORRANCE - ENGINEERING DEPARTMENT

DATE ISSUED

16 NOV 1998

WATER AND SEWER SEPARATION REQUIREMENTS

RICHARD W. BURTT
ENGINEERING DIRECTOR
R.C.E. NO. 32862



STANDARD NO.

T714-1

SHEET 2 OF 2